



NOTES:

- DETAILS SHOWN ARE MINIMUM DESIGN REQUIREMENTS.
- 3' MAXIMUM COVER.
- ALL CONCRETE 4,000 PSI @ 28 DAYS.
- REINFORCING 6"x6" / 10 GA.x10GA. THROUGHOUT.
- 1/2" REINFORCING BARS IN TANK TOP.
- EXCAVATION 1' LARGER ALL AROUND TANK.
- APPROX. WT: 9,200 LBS.

APR'D 03/02/05

REVISION	DATE	BY

STARK COUNTY
 SANITARY ENGINEERING DEPT.
 CHAPTER 22
 TYPICAL 1 PIECE GREASE
 TRAP/OIL INTERCEPTOR
 (NON-TRAFFIC)